



CMSV1030

bticino

Notification lamp outside the door. One colour notification LED lamp. It must be connected to the room terminal and installed in the corridor, outside the patient's room. IT can be used with 2 or 3 vertically installed lamps, to ensure completeness in the notifications. To be fitted with support and front cover plate. Each individual lamp uses 2 modules of the Mâtix range. White indicator for bathroom call notification

Technical features

Brand	BTicino
Reference Standard	VDE0834-1-2 (DIN 41050)
Rated voltage	27Vdc
Input current	50mA
Modules	2

Series

Commercial data

Minimum quantity	1
Sales unit	1
EAN code	8005543468012

Technical documentation

? DWG drawing

We, BTicino S.p.A. Viale Borri 231 21100 Varese (Italy), declare that all items listed in BTicino catalogues, have been manufactured in compliance with the principal elements of safety objectives of European Directive said LVD: 2014/35/EU: 26 February 2014 and, where requested, also in compliance with essential protection requirements of electromagnetic compatibility according to European Directive 2014/30/EU: 26 February 2014, and/or where requested also in compliance with 1995/5/CE: 9 March 1999 "R&TTE" or where requested also in compliance with 2014/53/EU: 16 April 2014 "RED". BTicino S.p.A. products are in compliance with the standard published by the International Electrotechnical Commission (IEC). The compliance can be proved by Certificates issued by organizations recognized by IEC according to the CB-scheme. Our items comply with relevant European Product- Standards and show, whether provided, CE marking, they have been constructed in accordance with good engineering practice in safety matters in force in the Community, they do not endanger the safety of persons, domestic animals or property when properly installed and maintained and used in applications for which they were made.