

# **GENERAL CATALOGUE**

# **CMTE3000**





Audio module for the audio function, the audio module is required. This includes microphone and loudspeakers. It can be installed: in the rooms, connected to the display room terminal, CMTE1200; in the main or secondary monitoring rooms, connected to the monitoring terminal, CMTE2200 or CMTE2300. It allows the audio communication - from room to room with nurse present - from monitoring room to room, following a call, or with nurse present; - from monitoring room to the whole department. For communications between patient and nurses, the additional microphone must be connected (items CMAS3010/11/20/30/40). It includes installation support and wiring for connection to the terminal. Device in antibacterial material

#### **Technical features**

# Commercial data

Brand	BTicino	Minimum quantity	1
Reference Standard	VDE0834-1-2 (DIN 41050)	Sales unit	1
Rated voltage	BUS/SCS	EAN code	8005543442357
Protection class	IP42		
Height	80mm		
Width	150mm		
Depth	27.8mm		
Series			

#### **Technical documentation**



We, BTicino S.p.A Viale Borri 231 21100 Varese (Italy), declare that all items listed in BTicino catalogues, have been manufactured in compliance with the principal elements of safety objectives of European Directive said LVD: 2014/35/EU: 26 February 2014 and, where requested, also in compliance with essential protection requirements of electromagnetic compatibility according to European Directive 2014/30/EU: 26 February 2014, and/or where requested also in compliance with 1995/5/CE: 9 March 1999 "R&TTE" or where requested also in compliance with 2014/53/EU: 16 April 2014 "RED". BTicino S.p.A. products are in compliance with the standard published by the International Electrotechnical Commission (IEC). The compliance can be proved by Certificates issued by organizations recognized by IEC according to the CB-scheme. Our items comply with relevant European Product- Standards and show, whether provided, CE marking, they have been constructed in accordance with good engineering practice in safety matters in force in the Community, they do not endanger the safety of persons, domestic animals or property when properly installed and



# **GENERAL CATALOGUE**

maintained and used in applications for which they were made.

# **Complete with**



## **CMAI1020**

Terminal support wall surface mount...



### **CMAI1120**

Desk base for terminal garrison with aud...



### **CMAI1010**

Terminal support wall surface mount...