

## Distributed by BTicino GENERAL CATALOGUE



## G725AS63



Earth leakage circuit breaker 2P - type A-S - In= 63A - Idn= 500mA - Vn= 230 Vac - 2 modules

Technical	features
-----------	----------

Brand	BTicino
Reference Standard	CEI EN 61008-1
Rated voltage	230Vac
Input current	63A
Differential current IDN	0.5A
Differential type	A-S
Modules	2
Poles	2P
Protection class	IP20
Height	83mm
Width	35.6mm
Depth	76mm
Maximum cable section	25/35mmq
Series	Btdin

## Commercial data

Minimum quantity	1
Sales unit	1
EAN code	8005543460092

## ? DWG drawing

Technical documentation

? Technical Data Sheet

? Instruction Sheet

We, BTicino S.p.A Viale Borri 231 21100 Varese (Italy), declare that all items listed in BTicino catalogues, have been manufactured in compliance with the principal elements of safety objectives of European Directive said LVD: 2014/35/EU: 26 February 2014 and, where requested, also in compliance with essential protection requirements of electromagnetic compatibility according to European Directive 2014/30/EU: 26 February 2014, and/or where requested also in compliance with 1999 'R&CTE' or where requested also in compliance with 2014/53/EU: 16 April 2014 'RED''. BTicino S.p.A. products are in compliance with the standard published by the International Electrotechnical Commission (IEC). The compliance can be proved by Certificates issued by organizations recognized by IEC according to the CB-scheme. Our items comply with relevant European Product- Standards and show, whether provided, CE marking, they have been constructed in accordance with good engineering practice in safety matters in force in the Community, they do not endanger the safety of persons, domestic animals or property when properly installed and maintained and used in applications for which they were made.

Source page: https://catalogue.bticino.com/product/low-voltage-energy-distribution/circuit-breakers-for-protection/btdin-miniature-circuit-breakers/earth-leakage-circuit-breakers/BTI-G725AS63-EN



Distributed by BTicino GENERAL CATALOGUE

Certifications

