



## H4651KNX



Axolute, 4 channel KNX control without finishing accessories.  
 Main functions: - 1 or 2 pushbuttons switch/dimmer - 1 or 2 pushbuttons shutter/shutter blade management - value forwarding (shutter position, dimmer %...) - forwarding of sequential values - forwarding of priority commands - forwarding of multiple commands - forwarding of conditional commands - recalling / saving of 1 and 8 bit scenarios Bus connection using a red-black KNX connector. SELV 29 Vdc supply voltage from KNX bus. Installation in residential series, to be completed with key covers, support and Axolute cover plate. Size: 2 modules.

### Technical features

Brand	BTicino
Reference Standard	EN 50090 - EN 13321-1 e ISO/IEC 14543-3
Rated voltage	29Vdc
Input current	2.5mA
Modules	2
Protection class	IP20-IK02
Plant type	KNX
Series	Axolute

### Commercial data

Minimum quantity	1
Sales unit	1
EAN code	8005543514306

### Technical documentation

? ETS Project File	? DWG drawing
? DWG drawing	? Instruction sheet
? Technical sheet	

We, BTicino S.p.A Viale Borri 231 21100 Varese (Italy), declare that all items listed in BTicino catalogues, have been manufactured in compliance with the principal elements of safety objectives of European Directive said LVD: 2014/35/EU: 26 February 2014 and, where requested, also in compliance with essential protection requirements of electromagnetic compatibility according to European Directive 2014/30/EU: 26 February 2014, and/or where requested also in compliance with 1995/5/CE: 9 March 1999 "R&TTE" or where requested also in compliance with 2014/53/EU: 16 April 2014 "RED". BTicino S.p.A. products are in compliance with the standard published by the International Electrotechnical Commission (IEC). The compliance can be proved by Certificates issued by organizations recognized by IEC according to the CB-scheme. Our items comply with relevant European Product- Standards and show, whether provided, CE marking, they have been constructed in accordance with good engineering practice in safety matters in force in the Community, they do not endanger the safety of persons, domestic animals or property when properly installed and maintained and used in applications for which they were made.