



T744L320MT

M4 630L - electronic circuit breaker (Lsig) 4P - In=320A - Icu=100kA - Ue= 690Vac - setting: Ir= 0.4-1In, Tr= 3-30s (overload) - Isd= 1.5-10In, Tsd= 0-0,3s (short-circuit) - Ig= 0.2-1Ir, Tg= 0.1-1s (earth fault) - with measuring function

Technical features

Brand	BTicino
Reference Standard	CEI EN 60947-2
Rated voltage	690Vac
Input current	320A
Breaking capacity ICU	100kA
Poles	4P
Height	260mm
Width	183mm
Depth	105mm
Series	MEGATIKER

Commercial data

Minimum quantity	1
Sales unit	1
EAN code	8005543550182

Technical documentation

? Instruction Sheet

? Instruction Sheet

? Technical Data Sheet

? Technical Data Sheet

We, BTicino S.p.A Viale Borri 231 21100 Varese (Italy), declare that all items listed in BTicino catalogues, have been manufactured in compliance with the principal elements of safety objectives of European Directive said LVD: 2014/35/EU: 26 February 2014 and, where requested, also in compliance with essential protection requirements of electromagnetic compatibility according to European Directive 2014/30/EU: 26 February 2014, and/or where requested also in compliance with 1995/5/CE: 9 March 1999 "R&TTE" or where requested also in compliance with 2014/53/EU: 16 April 2014 "RED". BTicino S.p.A. products are in compliance with the standard published by the International Electrotechnical Commission (IEC). The compliance can be proved by Certificates issued by organizations recognized by IEC according to the CB-scheme. Our items comply with relevant European Product- Standards and show, whether provided, CE marking, they have been constructed in accordance with good engineering practice in safety matters in force in the Community, they do not endanger the safety of persons, domestic animals or property when properly installed and maintained and used in applications for which they were made.

Complete with



T7081/400

GL400 underneath earth leakage module fo...



T7082/400

GS400 underneath earth leakage module fo...



M7045

Padlock block for MA/MH/ML400-630E and M...



M7295

Terminal shields to install between the ...