



# T804LE2500



Draw-out version air circuit breaker 4P - In= 2500A - Ue= 690Vac - Icu= 100kA - Frame 2

## Technical features

Brand	BTicino
Reference Standard	CEI EN 60947-2
Rated voltage	690Vac
Input current	2500A
Breaking capacity ICU	100kA
Poles	4P
Height	465mm
Width	544mm
Depth	403mm
Series	MEGABREAK

## Commercial data

Minimum quantity	1
Sales unit	1
EAN code	8012199963174

## Technical documentation

? Maintenance Guide	? Technical Data Sheet
? DWG drawing	? DWG Drawing
? Installation Manual	? Product Environmental Profile

We, BTicino S.p.A Viale Borri 231 21100 Varese (Italy), declare that all items listed in BTicino catalogues, have been manufactured in compliance with the principal elements of safety objectives of European Directive said LVD: 2014/35/EU: 26 February 2014 and, where requested, also in compliance with essential protection requirements of electromagnetic compatibility according to European Directive 2014/30/EU: 26 February 2014, and/or where requested also in compliance with 1995/5/CE: 9 March 1999 "R&TTE" or where requested also in compliance with 2014/53/EU: 16 April 2014 "RED". BTicino S.p.A. products are in compliance with the standard published by the International Electrotechnical Commission (IEC). The compliance can be proved by Certificates issued by organizations recognized by IEC according to the CB-scheme. Our items comply with relevant European Product- Standards and show, whether provided, CE marking, they have been constructed in accordance with good engineering practice in safety matters in force in the Community, they do not endanger the safety of persons, domestic animals or property when properly installed and maintained and used in applications for which they were made.

Complete with

**MP4/BA**

Standard electronic control unit with pr...

**MP4/SA**

Standard electronic control unit with pr...

**MP4/TA**

Standard electronic control unit with pr...

**MP6SH**

Touch screen electronic control unit wit...

**MP6TH**

Touch screen electronic control unit wit...