

# KRNEMOD4LE190

**IME**


Kit Nemo D4-Le + 3 current sensors Rogowski  $\varnothing$  190mm - Multifunction for application in LV - Network: single-phase or three-phase 3/4-wires unbalanced - Display: LCD backlit - Dimension: 4 DIN modules - Output: none - Current: 5A - by CT dedicated 5÷8000A (41 primary selectable range) - Output: pulse S0 / 1 alarm contact + RS485 BACnet - Input: 80÷500Vac - Auxiliary supply: 80÷265Vac or 100÷300Vdc

## Technical features

|                  |   |
|------------------|---|
| Brand            | IME   |
| Auxiliary        | 80-265Vac - 100-300Vdc                          |
| Input current    | 5A  |
| Modules          | 4   |
| Protection class | IP20  |
| Input            | 80-500Vac (3-PH) 50-290Vac (1-PH)               |
| Output           | impulsi / pulse + RS485 Modbus                  |
| Diameter         | 190mm   |
| visualization    | 5-8000A   |
| Plant type       | Trifase / three-phase + monofase / single-phase |
| insertion        | Rogowski  |

## Series

## Commercial data

|                  |               |
|------------------|---------------|
| Minimum quantity | 1             |
| Sales unit       | 1             |
| EAN code         | 8032826049613 |

## Technical documentation

- ? Technical sheet
- ? Protocol
- ? Firmware

We, BTicino S.p.A Viale Borri 231 21100 Varese (Italy), declare that all items listed in BTicino catalogues, have been manufactured in compliance with the principal elements of safety objectives of European Directive said LVD: 2014/35/EU: 26 February 2014 and, where requested, also in compliance with essential protection requirements of electromagnetic compatibility according to European Directive 2014/30/EU: 26 February 2014, and/or where requested also in compliance with 1995/5/CE: 9 March 1999 "R&TTE" or where requested also in compliance with 2014/53/EU: 16 April 2014 "RED". BTicino S.p.A. products are in compliance with the standard published by the International Electrotechnical Commission (IEC). The compliance can be proved by Certificates issued by organizations recognized by IEC according to the CB-scheme. Our items comply with relevant European Product- Standards and show, whether provided, CE marking, they have been constructed in accordance with good engineering practice in safety matters in force in the Community, they do not endanger the safety of persons, domestic animals or property when properly installed and maintained and used in applications for which they were made.

Complete with

---



### KRNEMOD4LE190

Kit Nemo 96HDLe + 3  
current sensors Rogo...