

GENERAL CATALOGUE



Series

KRNEMOHDLE080

IME

Kit Nemo 96HDLe + 3 current sensors Rogowski ø 80mm - Multifunction for application in LV - Network: single-phase or three-phase 3/4-wires unbalanced - Display: LCD backlit - Dimension: 4 DIN modules - Output: none - Current: 5A - by CT dedicated 5÷8000A (41 primary selectable range) - Output: pulse S0 / 1 alarm contact + RS485 MODBUS - Input: 80÷500Vac -Auxiliary supply: 80÷265Vac or 100÷300Vdc

Technical features		
Brand	IME	
Auxiliary	80-265Vac - 100-300Vdc	
Input current	5A	
Protection class	IP20	
Input	80-500Vac (3-PH) 50-290Vac (1-PH)	
Output	impulsi / pulse + RS485 Modbus	
Height	96mm	
Width	96mm	
Diameter	80mm	
visualization	5-8000A	
Plant type	Trifase / three-phase + monofase / single-phase	
insertion	Rogowski	

Minimum quantity	1	
Sales unit	1	
EAN code	8032826049620	

Commercial data

 $\textbf{Source page:}\ https://catalogue.bticino.com/product/solution-for-measurement-and-supervision-ime/nemo-multifunction-meters/flush-mounting-multifunction-meters/kitnemo-96hdle-with-rogowski-coil/IMS-KRNEMOHDLE080-EN$



GENERAL CATALOGUE

Technical documentation



↓ Protocol

↓ Technical Data Sheet

We, BTicino S.p.A Viale Borri 231 21100 Varese (Italy), declare that all items listed in BTicino catalogues, have been manufactured in compliance with the principal elements of safety objectives of European Directive said LVD: 2014/35/EU: 26 February 2014 and, where requested, also in compliance with essential protection requirements of electromagnetic compatibility according to European Directive 2014/30/EU: 26 February 2014, and/or where requested also in compliance with 1995/5/CE: 9 March 1999 "R&TTE" or where requested also in compliance with 2014/53/EU: 16 April 2014 "RED". BTicino S.p.A. products are in compliance with the standard published by the International Electrotechnical Commission (IEC). The compliance can be proved by Certificates issued by organizations recognized by IEC according to the CB-scheme. Our items comply with relevant European Product- Standards and show, whether provided, CE marking, they have been constructed in accordance with good engineering practice in safety matters in force in the Community, they do not endanger the safety of persons, domestic animals or property when properly installed and maintained and used in applications for which they were made.

Complete with



KRNEMOD4LE080

Kit Nemo D4-Le + 3 current sensors Rogow...



IF96001

Communication module RS485, protocol JBU...



IF96012

Memory module for Nemo 96HD/HD+...



IF96002

Communication module RS232, protocol JBU...



IF96007A

Communication module PROFIBUS EN 50170 f...



IF96009

Communication module LONWORKS for Nemo 9...



IF96013

Communication module Modbus EN1434-3...



IF96014

Communication module BACnet for Nemo 96H...



IF96015

Communication module Ethernet for Nemo 9...