



002665

KNX / DALI 1-channel interface capable of managing a maximum of 64 ballasts divided into 16 groups. Management via DALI presence sensors in 8 groups. Possibility to manage DALI ECK devices (emergency conversion kit) through configurable automatic test programs. Main characteristics: -16 groups of lights with 64 possible light scenarios, even overlapping - The addressing and grouping of the DALI devices takes place via a PC software downloadable from our website -maintaining constant light - burn-in function - "corridor" function with presence sensors - dimming - "sweep" function to switch off the lights Bus connection via red-black KNX connector. Power supply voltage 110-240 V 50-60 Hz. Installation on DIN rail. Dimensions: 4 DIN modules.

Technical features

Brand	Legrand
Reference Standard	EN 50090 - EN 13321-1 e ISO/IEC 14543-3
Rated voltage	29 Vd.c.
Input current	10 mA
Modules	4 DIN
Protection class	IP 20 e IK 04
Plant type	KNX
Series	KNX

Commercial data

Minimum quantity	1
Sales unit	1
EAN code	3414972052276

Technical documentation

? Technical sheet	? Instruction sheet
? ETS Project file	

We, BTicino S.p.A Viale Borri 231 21100 Varese (Italy), declare that all items listed in BTicino catalogues, have been manufactured in compliance with the principal elements of safety objectives of European Directive said LVD: 2014/35/EU: 26 February 2014 and, where requested, also in compliance with essential protection requirements of electromagnetic compatibility according to European Directive 2014/30/EU: 26 February 2014, and/or where requested also in compliance with 1995/5/CE: 9 March 1999 "R&TTE" or where requested also in compliance with 2014/53/EU: 16 April 2014 "RED". BTicino S.p.A. products are in compliance with the standard published by the International Electrotechnical Commission (IEC). The compliance can be proved by Certificates issued by organizations recognized by IEC according to the CB-scheme. Our items comply with relevant European Product- Standards and show, whether provided, CE marking, they have been constructed in accordance with good engineering practice in safety matters in force in the Community, they do not endanger the safety of persons, domestic animals or property when properly installed and maintained and used in applications for which they were made.