

002668

legrand®



KNX 1-10V 10-channel dimmer for the management of lamps interfaced through 1-10V ballasts. The device is also equipped with 10 16A contacts each for switching light loads. Each output can be managed via a button on board. Main functions: - Choice of operating mode normal / timer - Configuration of the behavior in case of reception of ON / dimming commands - Configuration of dimming values predefined - Hours of operation All functions can be used separately or together. In case of BUS absence and return, it is possible to configure the behavior of all the outputs with ETS. Bus connection via red-black KNX connector. Power supply SELV 29V d.c from KNX bus. DIN rail installation. Dimensions: 10 DIN modules.

Technical features

Brand	Legrand
Reference Standard	EN 50090 - EN 13321-1 e ISO/IEC 14543-3
Rated voltage	29 Vd.c.
Input current	10 mA
Modules	10 DIN
Protection class	IP 20 e IK 04
Plant type	KNX
Series	KNX

Commercial data

Minimum quantity	1
Sales unit	1
EAN code	3414972052283

Technical documentation

? Instruction sheet	? Technical sheet
? ETS Project file	

We, BTicino S.p.A Viale Borri 231 21100 Varese (Italy), declare that all items listed in BTicino catalogues, have been manufactured in compliance with the principal elements of safety objectives of European Directive said LVD: 2014/35/EU: 26 February 2014 and, where requested, also in compliance with essential protection requirements of electromagnetic compatibility according to European Directive 2014/30/EU: 26 February 2014, and/or where requested also in compliance with 1995/5/CE: 9 March 1999 "R&TTE" or where requested also in compliance with 2014/53/EU: 16 April 2014 "RED". BTicino S.p.A. products are in compliance with the standard published by the International Electrotechnical Commission (IEC). The compliance can be proved by Certificates issued by organizations recognized by IEC according to the CB-scheme. Our items comply with relevant European Product- Standards and show, whether provided, CE marking, they have been constructed in accordance with good engineering practice in safety matters in force in the Community, they do not endanger the safety of persons, domestic animals or property when properly installed and maintained and used in applications for which they were made.