



002698

legrand®

The KNX/DALI gateway ref. 0 026 98 is a DIN modular device equipped with 2 fully addressable DALI (Digital Addressable Lighting Interface) channels able to control up to 64 DALI ECGs each. DALI protocol allows not only to send switching/dimming commands but also to receive status informations, lamps failure informations and other error signals coming from DALI bus. Both KNX and DALI configuration is made with ETS and through its application program main possible functions are: - Switching, dimming or dimming value send - Operating sequence selection: normal, night, timer, constant light mode - Configure scene control (up to 32 scenes) - Configure power failure ballasts behaviour - Select error messages to report from DALI BUS (e.g. DALI device failure, DALI short circuit...) The KNX/DALI gateway ref. 0 026 98 is powered by main at 230 V a.c.

Technical features

Brand	Legrand
Reference Standard	EN 50090 - EN 13321-1 e ISO/IEC 14543-3
Rated voltage	29 Vdc
Input current	5 mA
Modules	4 DIN
Protection class	IP 20 e IK 04
Plant type	KNX

Series

Technical documentation

? Instruction Sheet

? Technical sheet

We, BTicino S.p.A Viale Borri 231 21100 Varese (Italy), declare that all items listed in BTicino catalogues, have been manufactured in compliance with the principal elements of safety objectives of European Directive said LVD: 2014/35/EU: 26 February 2014 and, where requested, also in compliance with essential protection requirements of electromagnetic compatibility according to European Directive 2014/30/EU: 26 February 2014, and/or where requested also in compliance with 1995/5/CE: 9 March 1999 "R&TTE" or where requested also in compliance with 2014/53/EU: 16 April 2014 "RED". BTicino S.p.A. products are in compliance with the standard published by the International Electrotechnical Commission (IEC). The compliance can be proved by Certificates issued by organizations recognized by IEC according to the CB-scheme. Our items comply with relevant European Product- Standards and show, whether provided, CE marking, they have been constructed in accordance with good engineering practice in safety matters in force in the Community, they do not endanger the safety of persons, domestic animals or property when properly installed and maintained and used in applications for which they were made.