

GENERAL CATALOGUE





003543

KNX/IP Gateway for the management of KNX systems using the web network. With built-in web server for access from the web browser of the PC or mobile device, it gives the possibility of displaying up to 40 KNX functions on a maximum of 5 pages Possible functions: switching/variation of light loads - control of motorised driving devices - temperature setting - selection of the operating mode and setting of the fan speed for HVAC devices - recalling of pre-configured scenarios - display of load status information Connection to the Bus using a red-black and white-yellow KNX connector. Supply voltage SELV 29 V d.c. from KNX bus. Fitting on DIN rail. Size: 5 DIN modules.

		C ,
100	hnianl	features
-(-	шисан	TEATHER

Brand	Legrand
Reference Standard	EN 50090 - EN 13321-1 e ISO/IEC 14543-3
Rated voltage	29Vdc
Modules	5 DIN
Protection class	IP20 - K04
Plant type	KNX
Series	

Commercial data

Minimum quantity 1

Sales unit 1

EAN code 3245060035433

Technical documentation

? DWG drawing

We, BTicino S.p.A Viale Borri 231 21100 Varese (Italy), declare that all items listed in BTicino catalogues, have been manufactured in compliance with the principal elements of safety objectives of European Directive said LVD: 2014/35/EU: 26 February 2014 and, where requested, also in compliance with essential protection requirements of electromagnetic compatibility according to European Directive 2014/30/EU: 26 February 2014, and/or where requested also in compliance with 1995/5/CE: 9 March 1999 "R&TTE" or where requested also in compliance with 2014/53/EU: 16 April 2014 "RED". BTicino S.p.A. products are in compliance with the standard published by the International Electrotechnical Commission (IEC). The compliance can be proved by Certificates issued by organizations recognized by IEC according to the CB-scheme. Our items comply with relevant European Product- Standards and show, whether provided, CE marking, they have been constructed in accordance with good engineering practice in safety matters in force in the Community, they do not endanger the safety of persons, domestic animals or property when properly installed and maintained and used in applications for which they were made.