□ legrand®







048884

Dimension 320x240, pixels 5.7" KNX touch screen display with backlighting LED. It gives the possibility of managing 40 KNX functions on 5 different pages. Possible functions: switching/variation of light loads - control of motorised driving devices - temperature setting - selection of the operating mode and setting of the fan speed for HVAC devices - recalling of preconfigured scenarios - display of load status information Bus connection using a red-black KNX connector. Supply voltage 29 Vdc SELV from KNX bus and supply voltage 230 Vac 50/60 Hz. Wall and flush mounted installation.

# Technical features

Brand	Legrand
Reference Standard	EN 50090 - EN 13321-1 e ISO/IEC 14543-3
Rated voltage	29 Vdc
Auxiliary	230 Vac
Frequency	50 Hz
Input current	4 ma (su bus) e 50 mA (230 Vac)
Protection class	IP 20 e IK 04
Height	130 mm
Width	157 mm
Depth	54 mm
Plant type	KNX

### Commercial data

Minimum quantity	1
Sales unit	1
EAN code	0000000000000

## Series

### Technical documentation

### ? DWG drawing

We, BTicino S.p.A Viale Borri 231 21100 Varese (Italy), declare that all items listed in BTicino catalogues, have been manufactured in compliance with the principal elements of safety objectives of European Directive said LVD: 2014/35/EU: 26 February 2014 and, where requested, also in compliance with essential protection requirements of electromagnetic compatibility according to European Directive 2014/30/EU: 26 February 2014, and/or where requested also in compliance with 1995/5/CE: 9 March 1999 "R&TTE" or where requested also in compliance with 2014/53/EU: 16 April 2014 "RED". BTicino S.p.A. products are in compliance with the standard published by the International Electrotechnical Commission (IEC). The compliance can be proved by Certificates issued by organizations recognized by IEC according to the CB-scheme. Our items comply with relevant European Product- Standards and show, whether provided, CE marking, they have been constructed in accordance with good engineering practice in safety matters in force in the Community, they do not endanger the safety of persons, domestic animals or property when properly installed and maintained and used in applications for which they were made.