



048919



Ceiling mounted KNX PIR sensor, IP20 protection index. Ideal for installation in the centre of the corridor Bus connection using a red-black KNX connector. SELV 29 Vdc supply voltage from KNX bus. Flush mounted false ceiling or masonry ceiling installation using flush mounting boxes or springs; ceiling mounted installation using accessory item 048875. White colour

Technical features

Brand	Legrand
Reference Standard	EN 50090 - EN 13321-1 e ISO/IEC 14543-3
Rated voltage	29 Vdc
Input current	7 mA
Protection class	IP 41 e IK 04
Diameter	Esterno 122 mm - incasso 52 mm
Plant type	KNX

Commercial data

Minimum quantity	1
Sales unit	1
EAN code	3245060489199

Series

Technical documentation

? Instruction sheet

? Technical sheet

? ETS Project File

We, BTicino S.p.A Viale Borri 231 21100 Varese (Italy), declare that all items listed in BTicino catalogues, have been manufactured in compliance with the principal elements of safety objectives of European Directive said LVD: 2014/35/EU: 26 February 2014 and, where requested, also in compliance with essential protection requirements of electromagnetic compatibility according to European Directive 2014/30/EU: 26 February 2014, and/or where requested also in compliance with 1995/5/CE: 9 March 1999 "R&TTE" or where requested also in compliance with 2014/53/EU: 16 April 2014 "RED". BTicino S.p.A. products are in compliance with the standard published by the International Electrotechnical Commission (IEC). The compliance can be proved by Certificates issued by organizations recognized by IEC according to the CB-scheme. Our items comply with relevant European Product- Standards and show, whether provided, CE marking, they have been constructed in accordance with good engineering practice in safety matters in force in the Community, they do not endanger the safety of persons, domestic animals or property when properly installed and maintained and used in applications for which they were made.

Complete with



048875

Box for surface ceiling installation , c...



088240

The base with the smartphone installed b...