

BTICINO &gt; Wiring devices &gt; Solutions for healthcare establishment &gt; Call system




## CMSV1030

Notification lamp outside the door. One colour notification LED lamp It must be connected to the room terminal and installed in the corridor, outside the patient's room. IT can be used with 2 or 3 vertically installed lamps, to ensure completeness in the notifications. To be fitted with support and front cover plate. Each individual lamp uses 2 modules of the Mâtix range. White indicator for bathroom call notification

### Technical features

|                    |                         |
|--------------------|-------------------------|
| Brand              | BTicino                 |
| Standard reference | VDE0834-1-2 (DIN 41050) |
| Rated voltage      | 27Vdc                   |
| Rated current      | 50mA                    |
| N° of modules      | 2                       |

### Documentation

 [\\_DWG drawing\\_](#)