

BTICINO &gt; Low voltage energy distribution &gt; BT DIN miniature circuit breakers &gt; Analogue and digital time switches





## F66GSW3

Daily analogue time switch - 24 hour dial, charge reserve 100 hours, minimum adjustment 15 minutes, summer/winter function, 1NO/NC contact - 230V/16A





### Technical features

Protection index	IP20
Height	83mm
Width	53mm
Depth	66mm
N° of modules	3
Standard reference	IEC 60730-1 - 60730-2-7
Rated voltage	230Vac
Contacts	1NO/NC
Rated current	16A
Series	Btdin

### Documentation

-  [Instructions Sheet](#)
-  [Catalogue BT DIN](#)

## Related products

			
<b>F66WSW3</b>	<b>F66GR3</b>	<b>F66SR3</b>	<b>F66GR1</b>
Weekly analogue time switch - 7 day dial, charge reserve 100 hours, minimum adjustment 2 hours, summ...	Daily analogue time switch - 24 hour dial, charge reserve 100 hours, minimum adjustment 15 minutes, ...	Weekly analogue time switch weekly, - 7 day dial, charge reserve 100 hours, minimum adjustment 2 hou...	Daily analogue time switch - daily, 24 hour vertical dial, charge reserve 100 hours, minimum adjustm...

We, Bticino S.p.A Viale Borri 231 21100 Varese (Italy), declare that all items listed in Bticino catalogues, have been manufactured in compliance with the principal elements of safety objectives of European Directive said LVD: 2014/35/EU: 26 February 2014 and, where requested, also in compliance with essential protection requirements of electromagnetic compatibility according to European Directive 2014/30/EU: 26 February 2014, and/or where requested also in compliance with 1995/5/CE: 9 March 1999 "R&TTE" or where requested also in compliance with 2014/53/EU: 16 April 2014 "RED". Bticino S.p.A. products are in compliance with the standard published by the International Electrotechnical Commission (IEC). The compliance can be proved by Certificates issued by organizations recognized by IEC according to the CB-scheme. Our items comply with relevant European Product- Standards and show, whether provided, CE marking, they have been constructed in accordance with good engineering practice in safety matters in force in the Community, they do not endanger the safety of persons, domestic animals or property when properly installed and maintained and used in applications for which they were made.