


BTICINO > Low voltage energy distribution > Circuit breakers for protection > MEGABREAK - Air circuit breakers > Contacts, coils, and releases





M8T415

Shunt trip for Megabreak - $V_n = 415\text{Vac}$





Technical features

Brand	BTicino
Standard reference	CEI EN 23-105
Rated voltage	415Vac
Series	Megabreak

Documentation

-  [Instruction Sheet](#)
-  [Catalogue Megabreak](#)

Related products

			
M8T024C	M8T048C	M8T110C	M8T230C
Shunt trip for Megabreak - $V_n = 24\text{Vac/dc}$	Shunt trip for Megabreak - $V_n = 48\text{Vac/dc}$	Shunt trip for Megabreak - $V_n = 110\text{Vac/dc}$	Shunt trip for Megabreak - $V_n = 230\text{Vac/dc}$

We, Bticino S.p.A Viale Borri 231 21100 Varese (Italy), declare that all items listed in Bticino catalogues, have been manufactured in compliance with the principal elements of safety objectives of European Directive said LVD: 2014/35/EU: 26 February 2014 and, where requested, also in compliance with essential protection requirements of electromagnetic compatibility according to European Directive 2014/30/EU: 26 February 2014, and/or where requested also in compliance with 1995/5/CE: 9 March 1999 "R&TTE" or where requested also in compliance with 2014/53/EU: 16 April 2014 "RED". Bticino S.p.A. products are in compliance with the standard published by the International Electrotechnical Commission (IEC). The compliance can be proved by Certificates issued by organizations recognized by IEC according to the CB-scheme. Our items comply with relevant European Product- Standards and show, whether provided, CE marking, they have been constructed in accordance with good engineering practice in safety matters in force in the Community, they do not endanger the safety of persons, domestic animals or property when properly installed and maintained and used in applications for which they were made.