



> MA/MH/ML160-250 circuit breakers > MA/MH/ML250E electronic



# T7314LA100T

ML250E electronic 4P - In=100A - Icu=100kA - Ue= 690Vac - 6 current and time settings for overload and short-circuit and earth fault

# **Technical features**

Brand	BTicino
Standard reference	CEI EN 60947-2
Rated voltage	690Vac
Rated current	100A
Ultimate breaking capacity	100kA
lcu	
N° of poles	4P
Height	200mm
Width	140mm
Depth	105mm
Series	MEGATIKER

## Documentation

Instruction Sheet

Instruction Sheet

## Related products



#### T7071/250

GL250 underneath earth leakage module for MA/MH/ML/MS250 -In=250A, Idn=0,03-3A, t=0-3s - signalizat...



### T7072/250

GS250 underneath earth leakage module for MA/MH/ML/MS250 -In=250A, Idn=0,03-3A, t=0-3s



#### T7073/250

GF250 underneath earth fault module for MA/MH/ML/MS250-250 E - In=250A



### M7025

Padlock block for MA/MH160, MS200 and MA/MH/ML/MS250-250



#### M7295

Terminal shields to install between the poles for MA/MH/ML/MS160-M 630E and MA/MH/ML630MT

We, BTicino S.p.A Viale Borri 231 21100 Varese (Italy), declare that all items listed in BTicino catalogues, have been manufactured in compliance with the principal elements of safety objectives of European Directive said LVD: 2014/35/EU: 26 February 2014 and, where requested, also in compliance with essential protection requirements of electromagnetic compatibility according to European Directive 2014/30/EU: 26 February 2014, and/or where requested also in compliance with 1995/SCE: 9 March 1999 "R&TTE" or where requested also in compliance with 2014/53/EU: 16 April 2014 "RED". BTicino S.p.A. products are in compliance with the standard published by the International Electrotechnical Commission (IEC). The compliance can be proved by Certificates issued by organizations recognized by IEC according to the CB-scheme. Our items comply with relevant European Product- Standards and show, whether provided, CE marking, they have been constructed in accordance with good engineering practice in safety matters in force in the Community, they do not endanger the safety of persons, domestic animals or property when properly installed and maintained and used in applications for which they were made.