

BTICINO > Low voltage energy distribution > Circuit breakers for protection > MEGABREAK - Air circuit breakers > Draw-out circuit breakers Icu=100kA






T803LE 1000

Draw-out version air circuit breaker 3P - In= 1000A - Ue= 690Vac
- Icu= 100kA - Frame 2

Technical features

Brand	BTicino
Standard reference	CEI EN 60947-2
Rated voltage	690Vac
Rated current	1000A
Ultimate breaking capacity Icu	100kA
N° of poles	3P
Height	465mm
Width	414mm
Depth	403mm
Series	MEGABREAK

Documentation

-  [Technical Data Sheet](#)
-  [_DWG drawing_](#)
-  [Environment. Product Declaration](#)

Related products

				
MP4/BA	MP4/SA	MP4/TA	MP6SH	MP6TH
Standard electronic control unit with protection LI (overload and shortcircuit)	Standard electronic control unit with protection LSI (overload and shortcircuit)	Standard electronic control unit with protection LSGI (overload, shortcircuit and earth fault)	Touch screen electronic control unit with protection LSI (overload and shortcircuit)	Touch screen electronic control unit with protection LSGI (overload, shortcircuit and earth fault)

We, BTicino S.p.A Viale Borri 231 21100 Varese (Italy), declare that all items listed in BTicino catalogues, have been manufactured in compliance with the principal elements of safety objectives of European Directive said LVD: 2014/35/EU: 26 February 2014 and, where requested, also in compliance with essential protection requirements of electromagnetic compatibility according to European Directive 2014/30/EU: 26 February 2014, and/or where requested also in compliance with 1995/5/CE: 9 March 1999 "R&TTE" or where requested also in compliance with 2014/53/EU: 16 April 2014 "RED". BTicino S.p.A. products are in compliance with the standard published by the International Electrotechnical Commission (IEC). The compliance can be proved by Certificates issued by organizations recognized by IEC according to the CB-scheme. Our items comply with relevant European Product- Standards and show, whether provided, CE marking, they have been constructed in accordance with good engineering practice in safety matters in force in the Community, they do not endanger the safety of persons, domestic animals or property when properly installed and maintained and used in applications for which they were made.