

## **GENERAL CATALOGUE**

BTICINO > Low voltage energy distribution > Circuit breakers for protection > MEGABREAK - Air circuit breakers > Fixed circuit breakers Icu=50kA



## T804A1250

Fixed version air circuit breaker 4P - In= 1250A - Ue= 690Vac - Icu= 50kA - Frame 1

## **Technical features**

# **Brand BTicino** CEI EN 60947-2 Standard reference Rated voltage 690Vac Rated current 1250A Ultimate breaking capacity 50kA lcu 4P N° of poles Height 414mm Width 358mm Depth 298mm Series **MEGABREAK**

# **Documentation**

Technical Data Sheet

DWG drawing

Environment. Product Declaration

Catalogue Megabreak

# Related products



#### MP4/BA

Standard electronic control unit with protection LI (overload and shortcircuit)



### MP4/SA

Standard electronic control unit with protection LSI (overload and shortcircuit)



#### MP4/TA

Standard electronic control unit with protection LSGI (overload, shortcircuit and earth fault)



### MP6SH

Touch screen electronic control unit with protection LSI (overload and shortcircuit)



#### MP6TH

Touch screen electronic control unit with protection LSGI (overload, shortcircuit and earth fault)

We, BTicino S.p.A Viale Borri 231 21100 Varese (Italy), declare that all items listed in BTicino catalogues, have been manufactured in compliance with the principal elements of safety objectives of European Directive said LVD: 2014/35/EU: 26 February 2014 and, where requested, also in compliance with essential protection requirements of electromagnetic compatibility according to European Directive 2014/30/EU: 26 February 2014, and/or where requested also in compliance with 1995/SCE: 9 March 1999 "R&TTE" or where requested also in compliance with 2014/53/EU: 16 April 2014 "RED". BTicino S.p.A. products are in compliance with the standard published by the International Electrotechnical Commission (IEC). The compliance can be proved by Certificates issued by organizations recognized by IEC according to the CB-scheme. Our items comply with relevant European Product- Standards and show, whether provided, CE marking, they have been constructed in accordance with good engineering practice in safety matters in force in the Community, they do not endanger the safety of persons, domestic animals or property when properly installed and maintained and used in applications for which they were made.