


GENERAL CATALOGUE

BTICINO > ZUCCHINI busbar > Medium power busbar > MR Medium Rating > Aluminium straight elements



50400266-2400

Data Center straight elements (IP40). Aluminium conductors and windows on both sides (4+4, step 600mm) - In=800A - IP40 - length 2,4m

Technical features

Brand	BTicino
Rated current	800A
Protection index	IP40
Length	2.4m

Documentation

Instruction Sheet

Busbar catalogue

Related products



50401006

Right feed unit from cabinet to transformers for busbar in Al MR800 -In=800A - IP55



50401126

Right feed unit (BIG) for busbar in Al MR800 -In=800A - IP55



50401206

Intermediate feed unit for busbar Al MR800 -In=800A - IP55



50400306

Horizontal elbow (right) in Al for MR800 -In=800A - IP55 - length 300+300mm



50400316

Horizontal elbow (left) in Al for MR800 - In=800A - IP55 - length 300+300mm



50400406

Vertical elbow (right) in Al for MR800 - In=800A - IP55



50400416

Vertical elbow (left) in Al for MR800 - In=800A -IP55



50401016

Left feed unit from cabinet to transformers for busbar in Al MR800 -In=800A - IP55



50401136

Left feed unit (BIG) for busbar in Al MR800 -In=800A - IP55

We, BTicino S.p.A Viale Borri 231 21100 Varese (Italy), declare that all items listed in BTicino catalogues, have been manufactured in compliance with the principal elements of safety objectives of European Directive said LVD: 2014/35/EU: 26 February 2014 and, where requested, also in compliance with essential protection requirements of electromagnetic compatibility according to European Directive 2014/30/EU: 26 February 2014, and/or where requested also in compliance with part of the products are in compliance with the standard published by the International Commission (IEC). The compliance can be proved by Certificates issued by organizations recognized by IEC according to the CB-scheme. Our items comply with relevant European Product- Standards and show, whether provided, CE marking, they have been constructed in accordance with good engineering practice in safety matters in force in the Community, they do not endanger the safety of persons, domestic animals or property when property installed and maintained and used in applications for which they were made.