


# **GENERAL CATALOGUE**

BTICINO > ZUCCHINI busbar > Medium power busbar > MR Medium Rating > T and cross elements



# 50403003

Cross element for busbar MR AI - In=315A - IP55

# **Technical features**

Brand	BTicino
Standard reference	CEI EN 61439-6
Rated voltage	1000Vac
Rated current	315A
Protection index	IP55
Series	MR

# **Documentation**

Installation manual

Instruction Sheet

Environment. Product Declaration

## Related products



### 50400243

Straight element MR315 Al without outlets -In=315A - IP52 - length



### 50400253

Straight element MR315 Al with 5 outlets on one side only - In=315A -IP52 - length 3m



### 50400103

Straight element MR315 Al with 3+3 outlets for side - In=315A - IP52 length 3m



### 50400123

Straight element MR315 Al without outlets -In=315A - IP52 - length 1-1.5m



### 50400153

Straight element MR315 Al with 2+2 outlets for side - In=315A - IP52 length 1.5-3m



#### 50400113

Straight element MR315 Al without outlets -In=315A - IP52 - length 0.6-1m



#### 50400143

Straight element MR315 Al with 1+1 outlets for side - In=315A - IP52 length 1-1.5m

We, BTicino S.p.A Viale Borri 231 21100 Varese (Italy), declare that all items listed in BTicino catalogues, have been manufactured in compliance with the principal elements of safety objectives of European Directive said LVD: 2014/35/EU: 26 February 2014 and, where requested, also in compliance with essential protection requirements of electromagnetic compatibility according to European Directive 2014/30/EU: 26 February 2014, and/or where requested also in compliance with 1995/SCE: 9 March 1999 "R&TTE" or where requested also in compliance with 2014/53/EU: 16 April 2014 "RED". BTicino S.p.A. products are in compliance with the standard published by the International Electrotechnical Commission (IEC). The compliance can be proved by Certificates issued by organizations recognized by IEC according to the CB-scheme. Our items comply with relevant European Product- Standards and show, whether provided, CE marking, they have been constructed in accordance with good engineering practice in safety matters in force in the Community, they do not endanger the safety of persons, domestic animals or property when properly installed and maintained and used in applications for which they were made.