

GENERAL CATALOGUE

BTICINO > ZUCCHINI busbar > Medium power busbar > MR Medium Rating > Copper straight elements



55400113

Straight element MR315 Cu without outlets - In=315A - IP52 - length 0.6-1m

Technical features

Brand BTicino Standard reference CEI EN 61439-6 Rated voltage 1000Vac Rated current 315A Protection index IP55 Length 0.61m Series MR

Documentation

Installation manual

Instruction Sheet

Related products



55403003

Cross element for busbar MR Cu -In=315A - IP55



55401003

Right feed unit from cabinet to transformers for busbar in Cu MR315 - In=315A - IP55



55401203

Intermediate feed unit for busbar Cu MR315 -In=315A - IP55



55401013

Left feed unit from cabinet to transformers for busbar in Cu MR315 - In=315A - IP55



55400413

Vertical elbow (left) in Cu for MR315 - In=315A - IP55



55400403

Vertical elbow (right) in Cu for MR315 - In=315A - IP55



55400313

Horizontal elbow (left) in Cu for MR315 - In=315A - IP55 - length 300+300mm



55400303

Horizontal elbow (right) in Cu for MR315 -In=315A - IP55 - length 300+300mm



55401133

Left feed unit (BIG) for busbar in Cu MR315 -In=315A - IP55



55401123

Right feed unit (BIG) for busbar in Cu MR315 -In=315A - IP55

We, BTicino S.p.A Viale Borri 231 21100 Varese (Italy), declare that all items listed in BTicino catalogues, have been manufactured in compliance with the principal elements of safety objectives of European Directive said LVD: 2014/35/EU: 26 February 2014 and, where requested also in compliance with essential protection requirements of electromagnetic compatibility according to European Directive 2014/30/EU: 26 February 2014, and/or where requested also in compliance with 2014/35/EU: 16 Pictinos S.p.A. products are in compliance with the standard published by the International Electrodechnical Commission (IEC). The compliance can be proved by Certificates issued by organizations recognized by IEC according to the CB-scheme. Our items comply with relevant European Product- Standards and show, whether provided, CE marking, they have been constructed in accordance with good engineering practice in safety matters in force in the Community, they do not endanger the safety of persons, domestic animals or property when properly installed and maintained and used in applications for which they were made.